

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# TAJ Flooring, Inc.

740 Church Road, Elgin, IL, United States

For the following product(s):

## Flooring Adhesives:

TAJ-1095 Premium Vinyl Flooring Adhesive; TAJ-U100 High Moisture Capable Wet Set Adhesive

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Standard Product Application Amount: 680.4 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): 0.5 – 5.0 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-07769

Valid from: March 28, 2022 to September 30, 2022

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA